

Goose Haven Energy Center, LLC

3853 Goose Haven Road
Suisun City, CA 94585

May 30, 2017

Director of Compliance and Enforcement
Bay Area Air Quality Management District
375 Beale Street, Suite 600
San Francisco, CA 94105
Attn: Title V

Subject: Goose Haven Energy Center, LLC
Title V Semi-Annual Monitoring Report
Facility # B4416
Reporting Period: November 1, 2016 – April 30, 2017

To Whom It May Concern:

Enclosed is the Title V CEMS Semi-Annual Monitoring Report for the Goose Haven Energy Center ("GHEC") for the reporting period from November 1, 2016 – April 30, 2017.

GHEC is currently in compliance with the District CEMS regulations. On April 5, 2017, the GHEC experience a malfunction of the NOx analyzer, this event caused erroneous emissions values to be recorded while the plant was operating and resulted in an indicated exceedance of the facility's daily mass emission limit for NOx. Further review of the data indicated that the plant operated in compliance with all applicable emissions limits during the time the NOx analyzer malfunction occurred. GHEC maintained compliance with the monitoring requirements listed in the Title V permit for GHEC during this reporting period.

By signing this report I am certifying that based on information and belief formed after reasonable inquiry, the statements and information in the attached report are true, accurate, and complete.

If you have any questions or require additional information, please contact me at (707) 399-4393.

Sincerely,



Andrew Gundershaug
Plant Manager and Designated Representative/Responsible Official

Table VII – A
Applicable Limits and Compliance Monitoring Requirements
S-1 – COMBUSTION GAS TURBINE
November 1, 2016 through April 30, 2017

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
NOx	BAAQMD 9-9-301.1.3	N		9 ppmv @ 15% O ₂ , dry	BAAQMD 9-9-501 and BAAQMD condition #20057, part 23c	C	CEM	X	
NOx	BAAQMD 9-9-301.1.3	N		9 ppmv @ 15% O ₂ , dry	BAAQMD condition #20057, part 24a	P/A	Source test every 8000 hrs or every 3 yrs, whichever comes first	X	
NOx	BAAQMD 9-9-301.2	N		.43 lbs/MW or 9 ppmv @ 15% O ₂ , dry	BAAQMD 9-9-501 and BAAQMD Condition #20057 part 23c	C	CEM	X	
NOx	SIP Regulation 9-9-301.3	Y		9ppmv @ 15% O ₂ , dry	BAAQMD 9-9-501 and BAAQMD condition #20057, part 23c	C	CEM	X	
	SIP Regulation 9-9-301.3	Y		9ppmv @ 15% O ₂ , dry	BAAQMD condition #20057, part 24a	P/A	Source test every 8000 hrs or every 3 yrs, whichever comes first	X	
NOx	NSPS, 40 CFR 60.332(a)(1)	Y		75ppmv @ 15% O ₂ , dry	NSPS 40CFR 60.334(c)	C	CEM	X	
NOx	None	Y		None	40 CFR 75.10	C	CEM	X	
NOx	BAAQMD condition #20057, part 18.1	Y		2.5 ppm @15% O ₂ , dry 3-hr rolling average except during turbine startup or shutdown	BAAQMD condition #20057, part 18.1	C	CEM	X	

Facility Name: Goose Haven Energy Center
Permit for Facility #: B4416

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
NOX	BAAQMD condition #20057, part 18.1	Y		2.5 ppm @15% O ₂ , dry 3-hr average except during turbine startup or shutdown	BAAQMD condition #20057, part 24a	P/A	Source test every 8000 hrs or every 3 yrs, whichever comes first	X	
NO _x	BAAQMD condition #2057, part 21	Y		121 lb/ calendar day (as NO ₂)	BAAQMD condition #20057, part 23c	C	CEM	X	
NO _x	BAAQMD condition #20057, part 21	Y		16.4 tons per calendar year (as NO ₂)	BAAQMD condition #20057, part 23c	C	CEM	X	
CO	BAAQMD condition #20057, part 18.3	Y		6 ppmv, @ 15% O ₂ , dry, 3-hr average except during turbine startup or shutdown	BAAQMD condition #20057, parts 18.3 and 23c	C	CEM	X	
CO	BAAQMD condition #20057, part 18.3	Y		6 ppmv, @ 15% O ₂ , dry, 3-hr average except during turbine startup or shutdown	BAAQMD condition #20057, part 24c	P/A	Source test every 8000 hrs or every 3 yrs, whichever comes first	X	
CO	BAAQMD condition #20057, part 21	Y		163 lb/ calendar day	BAAQMD condition #20057, part 23c	C	CEM	X	
CO	BAAQMD condition #20057, part 21	Y		29.1 tons per calendar year	BAAQMD condition #20057, part 23c	C	CEM	X	
CO ₂		Y		None	40 CFR 75.10	C	CEM (CO ₂) or CEM (O ₂) or fuel flow monitor	X	

Facility Name: Goose Haven Energy Center
Permit for Facility #: B4416

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
SO2	BAAQMD 9-1-301	Y		GLC ¹ of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		N		X	
SO2	BAAQMD 9-1-302	Y		300 ppm (dry)	BAAQMD condition #20057, part 23e	P/Q	Total Sulfur analysis	X	
SO2	NSPS 40 CFR 60.333(a)	Y		0.015% (vol) @ 15% O ₂ (dry)	NSPS 40 CFR 60.334(h)(3)		Fuel Measurements, calculations	X	
SO2	None	Y		None	40 CFR 75.11(d)(2), 40 CFR 75, Appendix D, part 2.3		Fuel measurements, calculations	X	
SO2	BAAQMD condition #20057, part 18.6	Y		1.39 lb/hr excluding startup and shutdown of turbines	BAAQMD condition #20057, part 23e	P/Q	Total sulfur content analysis	X	
SO2	BAAQMD condition #20057, part 18.6	Y		1.39 lb/hr excluding startup and shutdown of the turbines	BAAQMD condition #20057, part 24f	P/A	Source test every 8000 hrs or every 3 yrs, whichever comes first	X	
SO2	BAAQMD condition #20057, part 21	Y		33 lb/ calendar day	BAAQMD condition #20057, part 23e	P/Q	Total sulfur analysis	X	
SO2	BAAQMD condition #20057, part 21	Y		6.0 tons/ calendar year	BAAQMD condition #20057, part 23e	P/Q	Total sulfur analysis	X	
Opacity	BAAQMD 6-1-301	N		>Ringelmann No.1 for no more than 3 minutes in any hour		N		X	
Opacity	SIP 6-301	Y		>Ringelmann No.1 for no more than 3 minutes in any hour		N		X	

Facility Name: Goose Haven Energy Center
Permit for Facility #: B4416

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
Opacity	BAAQMD condition #20057, part 17	Y		> Ringelmann No.1 for no more than 3 minutes in any hour or equivalent 20% opacity		N		X	
Filterable Particulate	BAAQMD 6-1-310	N		0.15 grains/dscf		N		X	
Filterable Particulate	SIP 6-310	Y		0.15 grains/dscf		N		X	
PM10	BAAQMD condition #20057, part 18.5	Y		3 lb/hr for S-1	BAAQMD condition #20057, part 24e	P/A	Source test every 8000 hrs or every 3 yrs, whichever comes first	X	
PM10	BAAQMD condition #20057, part 21	Y		72 lb/ calendar day	BAAQMD condition #20057, parts 24e	P/A	Source test every 8000 hrs or every 3 yrs, whichever comes first	X	
PM10	BAAQMD condition #20057, part 21	Y		13.1 tons/ calendar year	BAAQMD condition #20057, part 24e	P/A	Source test every 8000 hrs or every 3 yrs, whichever comes first	X	
POC	BAAQMD condition #20057, part 18.4	Y		2 ppmv @ 15% O2, dry, except during turbine startup or shutdown	BAAQMD condition #20057, part 24d	P/A	Source test every 8000 hrs or every 3 yrs, whichever comes first	X	
POC	BAAQMD condition #20057, part 21	Y		30.0 lb/calendar day	BAAQMD condition #20057, part 24d	P/A	Source test every 8000 hrs or every 3 yrs, whichever comes first	X	
POC	BAAQMD condition #20057, part 21	Y		4.9 ton/ calendar year	BAAQMD condition #20057, part 24d	P/A	Source test every 8000 hrs or every 3 yrs, whichever comes first	X	

Facility Name: Goose Haven Energy Center
Permit for Facility #: B4416

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
NH3	BAAQMD condition #20057, part 18.2	N		10ppmv @15% O2, dry, except during turbine startup or shutdown	BAAQMD condition #20057, parts 18.2 and 23b	C	Calculation based on source test and NH3 to NOx ratio at inlet to SCR	X	
NH3	BAAQMD condition #20057, part 18.2	N		10ppmv @15% O2, dry, except during turbine startup or shutdown	BAAQMD condition #20057, part 24b	P/A	Source test every 8000 hrs or every 3 yrs, whichever comes first	X	
Heat input limit	BAAQMD condition #20057, part 22	Y		500 MMBTU/hr (HHV),	BAAQMD condition #20057, part 23d	C	Fuel meter,	X	
Heat input limit	BAAQMD condition #20057, part 22	Y		500 MMBTU/hr (HHV),	BAAQMD condition #20057, part 23d	P/M	Fuel composition analysis	X	
Heat input limit	BAAQMD condition #20057, part 22	Y		500 MMBTU/hr (HHV)	BAAQMD condition #20057, part 24g	P/A	Source test every 8000 hrs or every 3 yrs, whichever comes first	X	
Heat input limit	BAAQMD condition #20057, part 22	Y		12,000 MMBTU/day (HHV)	BAAQMD condition #20057, part 23d	C	Fuel meter, calculations	X	
Heat input limit	BAAQMD condition #20057, part 22	Y		12,000 MMBTU/day (HHV)	BAAQMD condition #20057, part 31g	P/Q	Fuel composition analysis	X	
Heat input limit	BAAQMD condition #20057, part 22	Y		4,380,000 MMBTU/yr	BAAQMD condition #20057, part 23d	C	Fuel meter, calculations	X	
Heat input limit	BAAQMD condition #20057, part 22	Y		4,380,000 MMBTU/yr	BAAQMD condition #20057, part 31g	P/Q	Fuel composition analysis	X	

Facility Name: Goose Haven Energy Center
Permit for Facility #: B4416

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
MW	N/A			None	BAAQMD condition #20057, part 24h	P/A	Source test every 8000 hrs or every 3 yrs, whichever comes first	X	
Exhaust Gas temperature	N/A			None	BAAQMD condition #20057, part 24j	P/A	Source test every 8000 hrs or every 3 yrs, whichever comes first	X	
Stack gas flow	N/A			None	BAAQMD condition #20057, part 24i	P/A	Source test every 8000 hrs or every 3 yrs, whichever comes first	X	
NH3 injection rate	N/A			None	BAAQMD condition #20057, part 24k, 18.2	P/A	Source test District approved correct ammonia slip calculation and correction factor determined by source test with source. Test every 8,000 hrs or every 3 yrs, Whichever comes first	X	
Start-up Period	BAAQMD Condition #20057 part 19			60 minutes per start-up	BAAQMD condition #2057, part 31(b)	P/E	Records	X	
Shutdown Period	BAAQMD Condition #20057 part 20			30 minutes per shutdown	BAAQMD condition #2057, part 31(b)	P/A	Records	X	
Fuel Sulfur Content	40 CFR 60.333(b)			0.8 percent by weight (8000ppmw) sulfur	40CRFR 60.334(h)(1)	P	Fuel Sulfur Content Testing	X	

Table VII - B
Applicable Limits and Compliance Monitoring Requirements
S-2 – DIESEL FIREWATER PUMP

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
SO ₂	BAAQMD 9-1-301 BAAQMD	N		GLC ¹ of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		P/E	Fuel certification by vendor	X	
	BAAQMD 9-1-304	Y		Sulfur content of fuel <0.5% by weight		P/E	Fuel certification by vendor	X	
Opacity	SIP Regulation 6-302	Y		<Ringelmann No. 2 for more than 3 min/hr		N		X	
Opacity	BAAQMD Regulation 6-1-302	N		<Ringelmann No. 2 for more than 3 min/hr		N		X	
FP	SIP Regulation 6-310	Y		0.15 grain/dscf		N		X	
FP	BAAQMD Regulation 6-1-310	N		0.15 grain/dscf		N		X	
Hours of operation	BAAQMD 9-8-330.1 BAAQMD Condition #22850 Part 1	Y		Emergency use for an unlimited number of hours	BAAQMD 9-8-530 BAAQMD Condition #22850 Part 3	C P/E	Hour meter, recordkeeping	X	
Hours of operation	BAAQMD 9-8-330.2 BAAQMD Condition #22850 Part 1	Y		Reliability-related activities not to exceed 50 hours in any consecutive 12-month period	BAAQMD Regulation 9-8-530 BAAQMD Condition #22850 Part 3	C P/E	Hour meter, recordkeeping	X	

Table VII - C
Applicable Limits and Compliance Monitoring Requirements
S-3 – COOLING TOWER

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
Opacity	BAAQMD Regulation 6-1-301	N		>=Ringelmann 1 for no more than 3 min/hr		N /		X	
Opacity	SIP Regulation 6-301	Y		>=Ringelmann 1 for no more than 3 min/hr		N		X	
Particulate Weight	BAAQMD Regulation 6-1-310	N		0.15 grains per dscf		N		X	
Particulate Weight	SIP Regulation 6-310	Y		0.15 grains per dscf		N		X	
Particulate Weight	BAAQMD Regulation 6-1-311	Y		40 lb/hr	N	N		X	
Particulate Weight	SIP Regulation 6-311	Y		40 lb/hr	N	N		X	